Load Test Report

Generator Model:	DQGAA-5745496	**Date:**	12/11/2025
kW Rating:	1250	**Technican:**	E&J Power Solutions
Serial Number:	L050862271	**Stock ID/Job #**	1533

Procedure: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load; **Record Data in 15 Min Intervals Prior to Load Steps.** If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in comments section below.

Time (Min)	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp. (F)
			A	B	C	A-B	A-C	B-C				
2:45	1%	22	59	57	55	481	480	480	60	91	153	62
3:00	50%	628	741	745	743	481	480	480	60	78	171	61
3:15	76%	950	1125	1130	1129	480	479	480	60	75	172	61
3:30	99%	1246	1465	1475	1475	480	479	479	60	73	174	61
3:45	99%	1244	1470	1474	1476	481	479	480	60	72	174	61

COMMENTS:

15814 Champion Forest Dr. #316 - Spring, TX 77379
www.ninexpower.com
281/813.4923