Load Test Report

Generator Model:	DFEK-5694693	**Date:**	**8/18/2025**
kW Rating:	500	**Technican:**	**E&J Power Solutions**
Serial Number:	K040711738	**Stock ID/Job #**	**1578**

Procedure: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load; **Record Data in 15 Min Intervals Prior to Load Steps.** If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in comments section below.

Time (Min)	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp. (F)
			A	B	C	A-B	A-C	B-C				
12:00	0	0	0	0	0	480	480	480	60	45	135	93
12:15	50%	250	302	302	301	477	478	478	60	40	181	94
12:30	75%	375	453	453	451	478	478	478	60	39	190	94
12:45	98%	492	593	595	591	476	476	476	60	37	202	95
13:00	98%	491	593	595	591	476	476	476	60	37	205	95

741.3 Hours

15814 Champion Forest Dr. #316 - Spring, TX 77379
www.ninexpower.com
281/813.4923