Load Test Report

Generator Model:	DQCA-7652092	**Date:**	**8/25/2025**
kW Rating:	600	**Technican:**	**E&J POWER SOLUTIONS**
Serial Number:	D090238553	**Stock ID/Job #**	**1600**

Procedure: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load; **Record Data in 15 Min Intervals Prior to Load Steps.** If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in comments section below.

Time (Min)	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp. (F)
			A	B	C	A-B	A-C	B-C				
12:30	0	0	0	0	0	480	481	481	60	74	157	91
12:45	50%	302	365	365	364	476	476	476	60	74	162	91
13:00	76%	456	546	547	545	479	478	479	60	72	171	92
13:15	99%	595	713	715	713	479	478	478	60	64	182	92
13:30	99%	594	713	715	713	477	478	478	60	63	186	93

COMMENTS:

15814 Champion Forest Dr. #316 - Spring, TX 77379
www.ninexpower.com
281/813.4923